

Corrigendum - I

RFP Reference Number :RFP IT-14/2021-22 dated 30-MAR-22

SrNo	RFP Heading	Existing Specification/RFP Clause	Page No	New Clause/Modification
1	4. Scope of Services and Terms & Conditions	Supply of FR Grade 12V 200 AH SMF Batteries with three years warranty. Proposed Batteries must be ABS container with FR grade	12	Modified as: Supply of FR Grade 12V 200 AH SMF Batteries with three years warranty.
2	Annexure - XII Technical Specifications	Battery Type: Batteries must be ABS container with FR grade	37	Modified as: Batteries must be FR grade battery

Note: All other clauses/Terms & conditions except above shall remain same as per RFP (RFP IT-14/2021-22 dated 30-MAR-22)