

**REQUEST FOR PROPOSAL FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 3x150KVA UPS & SMF BATTERIES
ALONG WITH 5 YEARS WARRANTY AT STOCKHOLDING'S MAHAPE OFFICE**

Sr. No	Page No	Description	Existing Clause			Amended Clause		
1	46	Annexure - 4 - Commercial bid format	Sr. No	Particulars		Sr.No	Particulars	
			1	150 KVA modular Hot swappable 3 x 3 with 250 KVA frame, with 50KW power module, BCB, Parallel Cable, Unity DP Card, Relay Card, three phase input/three Phase Output with five-year warranty		1	Revised Clause: 150 KVA modular Hot swappable 3 x 3 with 200 KVA frame, with 50KW power module, BCB, Parallel Cable, Unity DP Card, Relay Card, three phase input/three Phase Output with five-year warranty	
			Sr. No	Particulars	Description	Sr.No	Particulars	Description
2	16	1. Scope of Work	F	Requirements towards Electrical Work	vii. STANDARDS - Product should confirm to minimum applicable standards as IEC 62040-3 UPS PERFORMANCE, IEC 60950-, CE, VDE.	F	Requirements towards Electrical Work	Revised Clause: vii. STANDARDS - Product should confirm to minimum applicable standards as IEC 62040-3 (UPS PERFORMANCE), IEC 60950, CE, VDE or equivalent certifications.
3	24	2. UPS and Battery Specifications	F	Applicable Standards	g - Batteries shall comply with IS 15549 / IEC 60896 (VRLA)	F	Applicable Standards	Revised Clause: g - Batteries shall comply with The JIS C 8702:2009 , IS 16220 & IEC 61056.
4	19 & 40	2. UPS and Battery Specifications and II Specification of UPS and Battery	E & K	Bidder to submit GTP (Guaranteed Technical Particulars) for UPS in below format	4.18 - Overload a) 125 % 10 minutes b) 150 % 10 Sec	E & K	Bidder to submit GTP (Guaranteed Technical Particulars) for UPS in below format	Revised Clause: a) 125 % 60 Seconds b) 150 % 10 Seconds
5	17 & 38	2. UPS and Battery Specifications and II Specification of UPS and Battery	C & I	Environmental	Audible noise - <70 dbA	C & I	Environmental	Revised Clause: Audible Noise: <65 dbA

The last date for submission of bid has been extended to 18th August, 2026, 2PM

Note: All other clauses/Terms & conditions except above shall remain same as per RFP (RFP Reference Number: CPCM-28/2026-27)

Date : 10-Aug-2026		Addendum - 1 for RFP Reference Number: CPCM-28/2026-27	
REQUEST FOR PROPOSAL FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 3x150KVA UPS & SMF BATTERIES ALONG WITH 5 YEARS WARRANTY AT STOCKHOLDING’S MAHAPE OFFICE			
Sr. No	Page No	Description	Additional Clause
1	9	Criteria (Documents to be submitted online along with Technical Compliance)- Table A:	<u>Additional Clause:</u> Sr. No 10 (newly added) - Below certifications are included to ensure vendor credibility, product quality, environmental and safety compliance, operational efficiency, and cybersecurity assurance. Together, they guarantee that only qualified vendors with proven systems, financial stability, and readiness for future requirements can participate. This balances risk mitigation with long term sustainability for mission critical UPS installations. Certifications related to product quality, environmental, safety, energy, IT service, information security, and cybersecurity compliance (including VAPT) must be provided by the OEM. Certifications related to industry membership, state production authorization, and financial credibility must be provided by the bidding vendor. Both sets of certifications are mandatory to ensure product compliance and bidder credibility. - Mandatory Certification: IEEMA Membership State Production Certificate D&B financial credibility rating ISO 9001 (Quality), ISO 14001 (Environment), ISO 45001 (Safety) ISO 50001 (Energy Management) Desired Certifications: ISO 20000-1 (IT Service Management) ISO 27001 (Information Security) Future proof requirement: ISA/IEC 62443-1 compliance and CERT-IN VAPT are future-proofing requirements.
The last date for submission of bid has been extended to 18th August, 2026, 2PM Note: All other clauses/Terms & conditions except above shall remain same as per RFP (RFP Reference Number: CPCM-28/2026-27)			